

Existing Conditions - Super Splash USA



December 14, 2015

Super Splash



Current Conditions

Flume Slides

- Pump is aging- could fail in-season?

Main Pool & Plunge-

- Coating is failing
- Misc. Concrete Repair
- Substantial Water Loss (piping failing)

Avalanche & Drop Slides

- Structures rusting
- Operate as-is, until close?



Current Conditions



Current Conditions



Current Conditions

Pebble Beach

- Coating is in poor condition- needs full removal and replacement
- Piping has failed (staff has temporary recirc system)
- Substantial water loss
- Needs misc. equipment replaced
- Pool deck in poor to fair condition- offsets and cracking



Current Conditions



Current Conditions



Expanded Building

- Metal roof rusting

Catalina Cove

- Misc. Concrete Repairs
- Stress crack/ settlement
- Water loss/ piping issues
- Connecting ramp settling and cracking
- Hose bibb supply on deck has failed

Current Conditions



Current Conditions



Current Conditions

